

File Original and First Copy with  
Department of Ecology  
Second Copy—Owner's Copy  
Third Copy—Driller's Copy

**ENTERED**

# WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W-054332

Water Right Permit No. 32/2E/35-F 98293

(1) OWNER: Name DARRYL R. JONES

Address 2000 N. 35th ST. MT. VERNON, WA

(2) LOCATION OF WELL: County ISLAND

SE 1/4 NW 1/4 Sec. 35 T. 32 N. R. 2E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) 691 W 225N

CAMANO IS WA 98292

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater

(4) TYPE OF WORK: Owner's number of well  
(if more than one)

Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 472 feet. Depth of completed well 470 ft.

## (6) CONSTRUCTION DETAILS:

Casing installed: ☒ Diam. from 6 ft. to 470 ft.  
Welded ☒ Diam. from 43 ft. to 470 ft.  
Liner installed ☐ Threaded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒

Type of perforator used \_\_\_\_\_

SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☐ No ☒

Manufacturer's Name \_\_\_\_\_

Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to 20' ft.

Surface seal: Yes ☒ No ☐ To what depth? 20' ft.

Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name UNKNOWN

Type \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation above mean sea level \_\_\_\_\_ ft.

Static level 305 ft. below top of well Date 7/21/95

Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? \_\_\_\_\_

Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test \_\_\_\_\_

Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Airtest 20 gal./min. with stem set at 468 ft. for 1 hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☒

## (10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
TOP SOIL	0	3
GRAVEL, Cabbles & CLAY	3	16
HARD PAN	16	96
BROWN CLAY & GRAVEL	96	132
GRAY CLAY & GRAVEL	132	187
GRAVEL	187	256
BROWN SANDY CLAY	256	300
BROWN SILTY CLAY	300	367
With gravel	367	405
GRAY SILT CLAY	405	460
BROWN SILT & gravel	460	472
GRAVEL		

RECEIVED

AUG 8 1995

DEPT. OF ECOLOGY

Work started 7/17/95 Completed 7/21/95

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WATKINS Well Drilling Co.  
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 556 N SUNSET DR CAMANO IS, WA

(Signed) Ken Watkins License No. 0576  
(WELL DRILLER)

Contractor's Registration No. WATK WDL3AP2 Date 7/30/1995

(USE ADDITIONAL SHEETS IF NECESSARY)





WASHINGTON STATE  
DEPARTMENT OF  
ECOLOGY

# Well Tagging Form

066620 SOL

m

Unique Well Tag No: APR797

## RECORD VERIFICATION (check ☒ one)

- ☒ Well Report available (please attach this form to the well report and submit it to the Ecology Regional Office near you)
- ☐ Verification inconclusive
- ☐ Well Report not available

RECEIVED

MAR 23 2007

DEPT. OF ECOLOGY

## WELL OWNERSHIP IF DIFFERENT FROM WELL REPORT

Name: Jones Water Association

Street Address: c/o Kingwater Company, PO Box 2243

City: OAK Harbor

State: WA

WA 98277

## WELL LOCATION IF DIFFERENT FROM WELL REPORT

Well Address: 687 Majestic View Drive

Parcel R23235-280-1420

City: Camano Island

County: Island

T. 32N

R. 02E W.M.

Sec. 35

SE 1/4 of the NW 1/4

## FOR AGENCY USE ONLY

Latitude: 48 13.12177

Longitude: 122 31.25698



GPS



Topographic Map



Survey



Computer generated



Digital Altimeter



Topographic Map



Other: Computer Generated from

DEM and GPS XY Coordinates

Additional Information, if available:



Location marked on topographic map (please attach)



Location marked on air photo (please attach)

Tag placed and well  
GPS'd by:



# FOR AGENCY USE ONLY

## WELL CHARACTERISTICS

Physical Description of well (size of casing, type of well, housing, etc.)

6 In.Casing 8 Feet East of Pump House

Location of Well Identification Tag:

Strapped To Well Casing

Was supplemental tag needed for easy of identifying well?

☐

Yes

☒

No

If yes, where was tag placed?

D	C	B	A
E	F	G	H
M	L	K	J
N	P	Q	R

SECTION: 32N/02E-35

COMMENTS:

# FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

Water Right # \_\_\_\_\_

Date Issued: \_\_\_\_\_

Circle One:

Application

Permit

Certificate

Claim

Exempt

The Department of Ecology does NOT warrant the Data and/or the Information on this Well Report.

# WATER WELL REPORT

## State of Washington

IC Site ID: 3H3  
Start Card: W054332  
Water Right:

Unique Well ID

APR 79.7

- (1) **OWNER:** Name: Darryl R. Jones Address: 2000 N. 35th Street Mount Vernon , 98273
- (2) **LOCATION OF WELL:** Island: Camano Township/Range-Section: 32N/02E-35F Parcel Number: R23235-280-1420
- (2a) **Well Address** 691 W 225 N, Camano Island, WA 98292 PWS-ID: 06662Q Source: 1 PWS-Name: Jones Water Association

(3) **PROPOSED USE:** Domestic

(4) **TYPE OF WORK:** Owner's Well Number (if more than one):  
New Well Method: Rotary

(5) **DIMENSIONS:** Diameter of Well: 6 inches.  
Drilled: 472 feet. Depth of Completed Well: 470 ft.

(6) **CONSTRUCTION DETAILS:**

*Casing Installed:* Diam. (in) from to (ft)  
6 -3 470

*Screens:* Type Zone Diam Slot from to (ft)

*Surface seal:*  
Material: Bentonite To depth: 20 ft.

(7) **PUMP:**  
Type: Submersible Horsepower: 5

(8) **WATER LEVELS: 2** Land-surface elevation (MSL): ft.  
AvgWL Elevation: 1 Calc'd Elev: 306 ft.  
Earliest Level: 305.00 ft. below toc Date: 7/21/1995  
Lastest Level: 305.00 ft. below toc Date: 1/11/1996  
Average Level: 305.00 ft. below toc Average Date: 10/16/1995

(9) **WELL TESTS:**

Type	Yield	Drawdown	After	Date
Air Lift	20 gpm	4 feet	1 hours	7/21/1995
Pump	25 gpm	43.5 feet	4 hours	1/11/1996

(10) **WELL LOG DESCRIPTION:**

Material	From BGS	From MSL	Thick
Topsoil	0	306	3
Gravel, Cobbles & Clay	3	303	13
Hardpan	16	290	80
Brown Clay & Gravel	96	210	36
Gray Clay & Gravel	132	174	55
Gravel	187	119	69
Brown Sandy Clay	256	50	44
Brown Silty Clay	300	6	67
Gray Silt Clay	367	-61	38
Brown Silt & Gravel	405	-99	55
Gravel	460	-154	12
TD	472	-166	

Work Completed: 7/21/1995 TD Elev: -164 ft. MSL

**WELL CONSTRUCTOR CERTIFICATION:**

Name: Ken Watkins Well Drilling

Address: 556 N. Sunset Dr., Camano Island, WA 98292

Contractor's  
Registration Number: WATKIWD134

Remarks: Fireflow required.

Location Source: North: 449198 Latitd: 48° 13' 8.27"  
Parcel R23235-280-1420 East: 1588916 Longit: 122° 31' 14.3  
Max CL: 15.8 Generated by the Island County  
Max NO3: 0.25 Hydrogeologic Database: 1/17/2007

Disclaimer: Data presented has been collected from a variety of sources.  
Island County makes no guarantee as to the validity or accuracy of this data.  
Please report any errors to the Island County Hydrogeologist

File Original and First Copy with  
Department of Ecology  
Second Copy—Owner's Copy  
Third Copy—Driller's Copy

**ENTERED**

# WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W-054332

Water Right Permit No. 32/2E/35-F 98293

(1) OWNER: Name DARRYL R. JONES Address 2000 N. 35th St. Mt. Vernon, WA

(2) LOCATION OF WELL: County ISLAND SE 1/4 NW 1/4 Sec. 35 T. 32 N. R. 2E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) 691 W 225N CAMANO IS WA 98292

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) \_\_\_\_\_  
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 472 feet. Depth of completed well 470 ft.

## (6) CONSTRUCTION DETAILS:

Casing installed ☒ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Welded ☒ 6 Diam. from 43 ft. to 470 ft.  
Liner installed ☐  
Threaded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒

Type of perforator used \_\_\_\_\_

SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.

\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☐ No ☒

Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_

Type \_\_\_\_\_

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to 20' ft.

Surface seal: Yes ☒ No ☐ To what depth? Sealcrete ft.

Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name UNKNOWN

Type \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation above mean sea level \_\_\_\_\_ ft.

Static level 305 ft. below top of well Date 7/21/95

Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? \_\_\_\_\_

Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

" " " " " "

" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## (10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information

MATERIAL	FROM	TO
TOP SOIL	0	3
GRAVEL, CUBBLES & CLAY	3	16
HARD PAN	16	96
BROWN CLAY & GRAVEL	96	132
GRAY CLAY & GRAVEL	132	187
GRAVEL	187	256
BROWN SANDY CLAY	256	300
BROWN SILT & CLAY	300	367
WITH GRAVEL		
GRAY SILT CLAY	367	405
BROWN SILT & GRAVEL	405	460
GRAVEL	460	472

RECEIVED

AUG 8 1995

DEPT OF ECOLOGY

Work started 7/17/95 Completed 7/21/95

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WATKINS Well Drilling Co. (TYPE OR PRINT)

(PERSON, FIRM, OR CORPORATION)

Address 556 N SUNSET DR. CAMANO IS. WA

(Signed) Ken Watkins License No. 0576

(WELL DRILLER)

Contractor's Registration No. WATK WDL34P2 Date 7/30/1995

No. \_\_\_\_\_

(USE ADDITIONAL SHEETS IF NECESSARY)

